

| 1号機 | | | | | | | | |
|------|-------|-------------|-------|-------------|-------------|-------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 3/12 | 2:45 | 1300 | 500 | - | 0.800 | - | - | 0.941 |
| | 5:20 | 1300 | 500 | 2:45 | 0.800 | - | - | 0.941 |
| | 8:49 | -400 | -550 | 2:45 | 0.800 | - | 8:36 | 0.740 |
| | 10:04 | -500 | -700 | 2:45 | 0.800 | - | 9:20 | 0.740 |
| | 11:20 | -900 | -800 | 2:45 | 0.800 | - | 11:20 | 0.750 |
| | 12:05 | -1500 | -1400 | 2:45 | 0.800 | - | 12:05 | 0.750 |
| | 13:38 | -1700 | -1550 | 2:45 | 0.800 | - | 13:38 | 0.755 |
| | 14:41 | -1700 | -1650 | 2:45 | 0.800 | - | 14:41 | 0.610 |
| | 15:28 | -1700 | -1650 | 2:45 | 0.800 | - | 15:28 | 0.540 |
| 3/13 | 18:30 | D/S | D/S | - | - | - | - | - |
| | 1:00 | D/S | -1700 | 1:00 | - | - | - | - |
| | 2:00 | D/S | -1700 | 2:00 | - | - | - | - |
| | 8:00 | D/S | -1700 | 8:00 | 0.392 | - | - | - |
| | 8:55 | D/S | -1700 | 8:55 | 0.398 | - | - | 0.384 |
| | 13:00 | D/S | -1700 | 13:00 | 0.408 | - | - | - |
| | 16:00 | D/S | -1700 | 16:00 | 0.420 | - | 16:00 | 0.384 |
| | 17:30 | D/S | -1700 | 17:30 | 0.413 | - | 17:30 | 0.600 |
| | 18:45 | D/S | -1700 | 18:45 | 0.403 | - | 18:45 | 0.590 |
| | 21:40 | D/S | -1750 | 21:30 | 0.380 | - | 21:30 | 0.550 |
| 3/14 | 22:20 | D/S | -1750 | 22:20 | 0.370 | - | 22:20 | 0.540 |
| | 23:30 | D/S | -1750 | 23:30 | 0.056 | 0.360 | 23:30 | 0.384 |
| | 2:00 | D/S | -1700 | 2:00 | 0.040 | 0.350 | 2:00 | 0.510 |
| | 3:00 | D/S | -1700 | 3:00 | 0.032 | 0.340 | 3:00 | 0.505 |
| | 4:00 | D/S | -1700 | 4:00 | 0.032 | 0.338 | 4:00 | 0.495 |
| | 4:45 | D/S | -1700 | 4:45 | 0.034 | 0.299 | 4:45 | 0.490 |
| | 6:00 | -1700 | -1700 | 6:00 | 0.030 | 0.326 | 6:00 | 0.485 |
| | 7:00 | -1750 | -1750 | 7:00 | 0.036 | 0.320 | 7:00 | 0.475 |
| | 11:30 | -1800 | -1750 | 11:30 | 0.038 | 0.275 | 11:30 | 0.440 |
| | 13:00 | -1800 | -1750 | 13:00 | 0.040 | 0.306 | 13:00 | - |
| 3/15 | 16:00 | -1750 | -1750 | 16:00 | 0.052 | 0.300 | 16:00 | - |
| | 22:40 | -1700 | -1700 | 22:40 | 0.056 | 0.267 | 22:40 | - |
| | 3:00 | -1700 | -1700 | 3:00 | 0.068 | 0.248 | 3:00 | - |
| | 5:00 | -1750 | -1750 | 5:00 | 0.066 | 0.240 | 5:00 | - |
| | 13:00 | -1700 | -1700 | 13:00 | 0.076 | 0.206 | 13:00 | - |
| 3/16 | 18:43 | -1800 | -1800 | 18:43 | - | 0.188 | 18:43 | - |
| | 1:24 | -1800 | -1800 | 1:24 | 0.188 | - | 1:24 | - |
| | 1:54 | -1750 | -1750 | 1:54 | 0.176 | - | 1:54 | - |
| | 5:35 | -1800 | -1750 | 5:35 | 0.180 | - | 5:35 | - |
| 3/17 | 23:50 | -1800 | -1750 | 23:50 | 0.238 | 0.188 | 23:50 | - |
| | 3:10 | -1750 | -1750 | 3:10 | 0.220 | 0.172 | 3:10 | - |
| | 12:50 | -1700 | -1750 | 12:50 | 0.206 | 0.160 | 12:50 | - |
| 3/18 | 21:50 | -1700 | D/S | 21:50 | 0.192 | 0.168 | 21:50 | - |
| | 2:50 | -1700 | D/S | 2:50 | 0.182 | 0.158 | 2:50 | - |
| | 16:00 | -1700 | -1800 | 16:00 | 0.212 | 0.170 | 16:00 | 0.180 |
| 3/19 | 21:10 | -1750 | -1800 | 21:10 | 0.216 | 0.168 | 21:10 | 0.180 |
| | 3:30 | -1750 | -1750 | 3:30 | 0.228 | 0.172 | 3:30 | 0.180 |
| | 16:50 | -1750 | -1750 | 16:50 | 0.228 | 0.178 | 16:50 | 0.180 |
| | 22:30 | -1750 | -1750 | 22:30 | 0.228 | 0.182 | 22:30 | 0.180 |

| 1号機 | | | | | | | | |
|------|-------|-------------|-------|-------------|-------------|-------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 3/20 | 0:00 | -1750 | -1750 | 0:00 | 0.228 | 0.186 | 0:00 | 0.180 |
| | 5:00 | -1750 | -1750 | 5:00 | 0.226 | 0.180 | 5:00 | 0.180 |
| | 15:00 | -1700 | -1750 | 15:00 | 0.208 | 0.176 | 15:00 | 0.170 |
| 3/21 | 3:00 | -1750 | -1800 | 3:00 | 0.216 | 0.176 | 3:00 | 0.160 |
| | 8:00 | -1750 | -1750 | 8:00 | 0.196 | 0.164 | 8:00 | 0.160 |
| | 14:25 | -1750 | -1750 | 14:25 | 0.220 | 0.190 | 14:25 | 0.160 |
| 3/22 | 0:15 | -1750 | -1700 | 0:15 | 0.218 | 0.171 | 0:15 | 0.160 |
| | 6:00 | -1750 | -1700 | 6:00 | 0.218 | 0.186 | 6:00 | 0.160 |
| | 11:20 | -1800 | -1750 | 11:20 | 0.252 | 0.228 | 11:20 | 0.175 |
| | 15:30 | -1800 | -1750 | 15:30 | 0.240 | 0.188 | 15:30 | 0.180 |
| 3/23 | 23:00 | -1750 | -1750 | 23:00 | 0.246 | 0.218 | 23:00 | 0.185 |
| | 4:00 | -1750 | -1750 | 4:00 | 0.336 | 0.300 | 4:00 | 0.260 |
| | 12:00 | -1750 | -1750 | 12:00 | 0.396 | 0.356 | 12:00 | 0.320 |
| | 14:00 | -1700 | -1700 | 14:00 | 0.418 | 0.398 | 14:00 | 0.345 |
| | 16:00 | -1750 | -1700 | 16:00 | 0.422 | 0.398 | 16:00 | 0.360 |
| 3/24 | 21:00 | -1700 | -1650 | 21:00 | 0.440 | 0.416 | 21:00 | 0.375 |
| | 1:00 | -1700 | -1700 | 1:00 | 0.456 | 0.430 | 1:00 | 0.385 |
| | 7:00 | -1700 | -1700 | 7:00 | 0.480 | 0.450 | 7:00 | 0.400 |
| | 11:00 | -1700 | -1700 | 11:00 | 0.480 | 0.446 | 11:00 | 0.400 |
| | 13:00 | -1700 | -1650 | 13:00 | 0.470 | 0.430 | 13:00 | 0.390 |
| 3/25 | 17:00 | -1650 | -1650 | 17:00 | 0.488 | 0.408 | 17:00 | 0.355 |
| | 20:00 | -1700 | -1650 | 20:00 | 0.430 | 0.402 | 20:00 | 0.345 |
| | 22:00 | -1700 | -1650 | 22:00 | 0.422 | 0.388 | 22:00 | 0.325 |
| | 2:00 | -1700 | -1650 | 2:00 | 0.418 | 0.398 | 2:00 | 0.325 |
| | 6:00 | -1700 | -1650 | 6:00 | 0.406 | 0.390 | 6:00 | 0.310 |
| | 10:00 | -1650 | -1650 | 10:00 | 0.388 | 0.388 | 10:00 | 0.295 |
| | 14:00 | -1650 | -1600 | 14:00 | 0.380 | 0.388 | 14:00 | 0.280 |
| 3/26 | 16:30 | -1650 | -1600 | 16:30 | 0.380 | 0.380 | 16:30 | 0.275 |
| | 18:30 | -1650 | -1600 | 18:30 | 0.376 | 0.376 | 18:30 | 0.275 |
| | 5:00 | -1650 | -1600 | 5:00 | 0.392 | 0.400 | 5:00 | 0.270 |
| | 9:30 | -1650 | -1600 | 9:30 | 0.418 | 0.400 | 9:30 | 0.270 |
| | 13:00 | -1650 | -1600 | 13:00 | 0.390 | 0.422 | 13:00 | 0.275 |
| 3/27 | 21:00 | -1650 | -1650 | 21:00 | 0.406 | 0.432 | 21:00 | 0.270 |
| | 5:00 | -1650 | -1600 | 5:00 | 0.412 | 0.452 | 5:00 | 0.270 |
| | 9:00 | -1650 | -1600 | 9:00 | 0.416 | 0.462 | 9:00 | 0.270 |
| | 15:30 | -1650 | -1650 | 15:30 | 0.412 | 0.476 | 15:30 | 0.270 |
| 3/28 | 16:20 | -1650 | -1650 | 16:20 | 0.410 | 0.482 | 16:20 | 0.265 |
| | 0:00 | -1650 | -1600 | 0:00 | 0.416 | 0.492 | 0:00 | 0.270 |
| | 3:00 | -1700 | -1650 | 3:00 | 0.418 | 0.492 | 3:00 | 0.270 |
| | 12:30 | -1700 | -1650 | 12:30 | 0.418 | 0.502 | 12:30 | 0.270 |
| 3/29 | 17:30 | -1650 | -1650 | 17:30 | 0.422 | 0.528 | 17:30 | 0.280 |
| | 1:00 | -1500 | -1650 | 1:00 | 0.438 | 0.556 | 1:00 | 0.290 |
| | 4:00 | -1600 | -1600 | 4:00 | 0.436 | 0.558 | 4:00 | 0.285 |
| | 9:40 | -1650 | -1650 | 9:40 | 0.426 | 0.546 | 9:40 | 0.275 |
| | 13:00 | -1650 | -1600 | 13:00 | 0.412 | 0.546 | 13:00 | 0.265 |
| | 16:00 | -1650 | -1600 | 16:00 | 0.408 | 0.546 | 16:00 | 0.265 |
| 3/30 | 4:00 | -1600 | -1600 | 4:00 | 0.392 | 0.542 | 4:00 | 0.235 |
| | 14:00 | -1600 | -1600 | 13:00 | 0.378 | 0.546 | 13:00 | 0.230 |
| | 16:00 | -1600 | -1600 | 16:00 | 0.366 | 0.538 | 16:00 | 0.230 |
| | 18:00 | -1600 | -1600 | 18:00 | 0.366 | 0.538 | 18:00 | 0.225 |
| 3/31 | 2:00 | -1600 | -1600 | 2:00 | 0.362 | 0.552 | 2:00 | 0.210 |
| | 4:00 | -1650 | -1600 | 4:00 | 0.370 | 0.568 | 4:00 | 0.210 |
| | 8:00 | -1650 | -1650 | 8:00 | 0.366 | 0.550 | 8:00 | 0.210 |
| | 16:00 | -1600 | -1550 | 16:00 | 0.350 | 0.552 | 16:00 | 0.190 |

| 1号機 | | | | | | | | |
|-----|-------|-------------|-------|-------------|-------------|-------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 4/1 | 0:00 | -1650 | -1650 | 0:00 | 0.326 | 0.536 | 0:00 | 0.175 |
| | 6:00 | -1600 | -1600 | 6:00 | 0.326 | 0.550 | 6:00 | 0.170 |
| | 10:00 | -1650 | -1650 | 10:00 | 0.328 | 0.552 | 10:00 | 0.165 |
| | 17:00 | -1600 | -1600 | 17:00 | 0.326 | 0.560 | 17:00 | 0.160 |
| 4/2 | 0:30 | -1600 | -1600 | 0:30 | 0.310 | 0.566 | 0:30 | 0.160 |
| | 4:00 | -1600 | -1600 | 4:00 | 0.320 | 0.578 | 4:00 | 0.160 |
| | 12:00 | -1650 | -1650 | 12:00 | 0.322 | 0.590 | 12:00 | 0.155 |
| | 16:30 | -1650 | -1650 | 16:30 | 0.316 | 0.598 | 16:30 | 0.155 |
| 4/3 | 3:00 | -1650 | -1650 | 3:00 | 0.322 | 0.602 | 3:00 | 0.155 |
| | 9:00 | -1650 | -1650 | 9:00 | 0.326 | 0.608 | 9:00 | 0.155 |
| | 14:00 | -1650 | -1650 | 14:00 | 0.328 | 0.618 | 14:00 | 0.155 |
| 4/4 | 0:00 | -1650 | -1650 | 0:00 | 0.338 | 0.658 | 0:00 | 0.155 |
| | 6:00 | -1700 | -1650 | 6:00 | 0.338 | 0.670 | 6:00 | 0.150 |
| | 11:00 | -1650 | -1650 | 11:00 | 0.332 | 0.670 | 11:00 | 0.150 |
| 4/5 | 0:00 | -1700 | -1650 | 0:00 | 0.338 | 0.672 | 0:00 | 0.150 |
| | 6:00 | -1700 | -1650 | 6:00 | 0.342 | 0.688 | 6:00 | 0.150 |
| | 18:00 | -1650 | -1650 | 18:00 | 0.338 | 0.718 | 18:00 | 0.150 |
| 4/6 | 0:00 | -1650 | -1650 | 0:00 | 0.338 | 0.703 | 0:00 | 0.150 |
| | 6:00 | -1650 | -1700 | 6:00 | 0.350 | 0.723 | 6:00 | 0.150 |
| | 12:00 | -1650 | -1650 | 12:00 | 0.348 | 0.725 | 12:00 | 0.150 |
| | 18:00 | -1650 | -1650 | 18:00 | 0.350 | 0.720 | 18:00 | 0.150 |
| 4/7 | 0:00 | -1650 | -1650 | 0:00 | 0.355 | 0.735 | 0:00 | 0.150 |
| | 6:00 | -1650 | -1650 | 6:00 | 0.363 | 0.758 | 6:00 | 0.155 |
| | 12:00 | -1650 | -1650 | 12:00 | 0.375 | 0.758 | 12:00 | 0.165 |
| | 18:00 | -1650 | -1650 | 18:00 | 0.380 | 0.773 | 18:00 | 0.175 |
| 4/8 | 0:00 | -1650 | -1650 | 0:00 | 0.390 | 0.788 | 0:00 | 0.180 |
| | 6:00 | | | 6:00 | | | 6:00 | |
| | 12:00 | | | 12:00 | | | 12:00 | |
| | 18:00 | | | 18:00 | | | 18:00 | |

* 1号機・3号機の原子炉圧力については、東電においてデジタル電圧計の測定値の換算式の見直しがあったため、3月13日～4月6日分を修正。

| 2号機 | | | | | | | | |
|------|-------|-------------|-------|-------------|-------------|--------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 3/11 | 22:00 | 3400 | - | - | - | - | - | - |
| 3/12 | 2:55 | 3700 | - | - | 5.600 | - | - | 0.161 |
| | 5:20 | 3700 | - | 2:55 | 5.600 | - | - | 0.161 |
| | 2:45 | 3600 | - | 2:55 | 5.600 | - | - | 0.161 |
| | 9:30 | 3600 | - | 2:55 | 5.600 | - | - | 0.161 |
| | 11:20 | 3600 | - | 2:55 | 5.600 | - | - | 0.161 |
| | 11:30 | 3600 | - | 2:55 | 5.600 | - | - | 0.151 |
| | 13:38 | 3600 | - | 12:55 | 6.100 | - | 12:55 | 0.110 |
| | 14:10 | 3600 | - | 12:55 | 6.100 | - | 12:55 | 0.110 |
| | 14:50 | 3600 | - | 12:55 | 6.100 | - | 12:55 | 0.110 |
| | 18:30 | 3550 | - | 18:30 | 6.300 | - | 18:30 | 0.155 |
| 3/13 | 1:00 | 3650 | - | 18:30 | 6.300 | - | 18:30 | 0.155 |
| | 2:00 | 3650 | - | 18:30 | 6.300 | - | 18:30 | 0.155 |
| | 8:00 | 3650 | - | 8:00 | 6.100 | - | - | 0.350 |
| | 8:55 | 3700 | | 8:55 | 6.080 | | 8:55 | 0.360 |
| | 13:00 | - | 3750 | 12:40 | - | - | 13:00 | 0.595 |
| | 16:00 | - | 3750 | 16:00 | 5.850 | | 16:00 | 0.400 |
| | 16:30 | 3750 | 3750 | 17:30 | 5.280 | | 17:30 | 0.410 |
| | 18:45 | 3800 | 3750 | 18:45 | - | - | 18:45 | 0.410 |
| | 21:30 | 3800 | 3800 | 21:00 | - | - | 21:30 | 0.425 |
| | 22:30 | 3850 | 3900 | 22:30 | - | - | 22:30 | 0.430 |
| 3/14 | 23:30 | 3850 | 3900 | 23:30 | - | - | 23:30 | 0.435 |
| | 0:00 | 3850 | 3900 | 0:00 | - | - | 0:00 | 0.435 |
| | 2:00 | 3850 | 3900 | - | - | - | 2:00 | 0.440 |
| | 3:00 | 3850 | 3900 | 3:00 | 5.450 | 5.450 | 3:00 | - |
| | 4:00 | 3850 | 3900 | 4:00 | 5.420 | 5.420 | 4:00 | - |
| | 4:00 | 3850 | 3900 | 4:30 | 5.400 | 5.400 | 4:30 | - |
| | 5:30 | 3900 | 3900 | 5:30 | 5.400 | 5.400 | 5:30 | - |
| | 6:30 | 3900 | 3900 | 6:30 | 5.355 | 5.355 | 6:30 | - |
| | 10:30 | 3800 | 3850 | 10:30 | 5.648 | 5.648 | 10:30 | 0.460 |
| | 12:30 | 2950 | 3000 | 12:30 | 6.188 | 6.188 | 12:30 | 0.465 |
| | 17:12 | D/S | D/S | 17:12 | 7.403 | | 17:12 | - |
| | 19:03 | D/S | D/S | 19:03 | 0.630 | | 19:03 | 0.400 |
| | 22:40 | -700 | -700 | 22:40 | 0.428 | | 22:40 | 0.428 |
| | 23:54 | D/S | D/S | 23:50 | 0.653 | | 23:54 | 0.745 |
| 3/15 | 0:45 | D/S | D/S | 0:45 | 1.823 | | 0:41 | 0.720 |
| | 1:53 | D/S | D/S | 1:53 | 0.630 | | 1:53 | 0.725 |
| | 3:00 | D/S | D/S | 3:00 | 0.653 | | 3:00 | 0.750 |
| | 6:20 | -2700 | -2700 | 6:20 | 0.612 | | 6:20 | 0.730 |
| | 13:00 | -1700 | 700 | 13:00 | 0.608 | | 13:00 | 0.415 |
| | 18:43 | -1200 | - | 18:43 | 0.099 | | 18:43 | 0.250 |
| 3/16 | 1:24 | -1400 | - | 1:24 | -0.023 | | 1:24 | 0.320 |
| | 1:54 | -1400 | - | 1:54 | -0.023 | | 1:54 | 0~0.24 |
| | 5:35 | -1500 | - | 5:35 | -0.041 | -0.059 | 5:35 | 0~0.22 |
| | 23:50 | -1400 | - | 23:50 | -0.063 | -0.079 | 23:50 | 0.075 |
| 3/17 | 3:10 | -1400 | - | 3:10 | -0.065 | -0.079 | 3:10 | 0.075 |
| | 12:50 | -1800 | - | 12:50 | -0.027 | -0.045 | 12:50 | 0.110 |
| | 21:40 | -1400 | - | 21:50 | -0.027 | -0.045 | 12:50 | 0.130 |
| 3/18 | 2:50 | -1400 | - | 2:50 | -0.016 | -0.032 | 2:50 | 0.130 |
| | 16:00 | -1400 | - | 16:00 | -0.002 | -0.018 | 16:00 | 0.139 |
| | 21:10 | -1400 | - | 21:10 | -0.005 | -0.020 | 21:10 | 0.140 |
| 3/19 | 3:30 | -1400 | - | 3:30 | -0.005 | -0.018 | 3:30 | 0.135 |
| | 16:30 | -1300 | - | 16:30 | -0.009 | -0.025 | 16:30 | 0.135 |
| | 22:30 | -1350 | - | 22:30 | 0.009 | -0.023 | 22:30 | 0.130 |

| 2号機 | | | | | | | | |
|------|-------|-------------|-----|-------------|-------------|--------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 3/20 | 0:00 | -1300 | - | 0:00 | -0.007 | -0.023 | 0:00 | 0.130 |
| | 5:00 | -1300 | - | 5:00 | -0.014 | -0.029 | 5:00 | 0.180 |
| | 15:00 | -1400 | - | 15:00 | -0.016 | -0.020 | 15:00 | 0.125 |
| 3/21 | 3:00 | -1350 | - | 3:00 | -0.018 | -0.020 | 3:00 | 0.120 |
| | 8:00 | -1350 | - | 8:00 | -0.020 | -0.020 | 8:00 | 0.120 |
| | 14:25 | -1350 | - | 14:25 | -0.023 | -0.025 | 14:25 | 0.120 |
| 3/22 | 0:15 | -1400 | - | 0:15 | -0.025 | -0.027 | 0:15 | 0.110 |
| | 6:00 | -1350 | - | 6:00 | -0.005 | -0.029 | 6:00 | 0.110 |
| | 11:20 | -1350 | - | 11:20 | -0.018 | -0.018 | 11:20 | 0.110 |
| | 15:30 | -1300 | - | 15:30 | -0.029 | -0.032 | 15:30 | 0.110 |
| 3/23 | 23:00 | -1350 | - | 23:00 | -0.020 | -0.043 | 23:00 | 0.110 |
| | 4:20 | -1300 | - | 4:20 | -0.025 | -0.025 | 4:20 | 0.110 |
| | 9:00 | -1300 | - | 9:00 | -0.023 | -0.023 | 9:00 | 0.110 |
| | 14:00 | -1250 | - | 14:00 | -0.036 | -0.036 | 14:00 | 0.110 |
| 3/24 | 21:00 | -1200 | - | 21:00 | -0.036 | -0.036 | 21:00 | 0.110 |
| | 1:00 | -1200 | - | 1:00 | -0.025 | -0.025 | 1:00 | 0.105 |
| | 9:00 | -1150 | - | 9:00 | -0.135 | -0.038 | 9:00 | 0.110 |
| | 13:00 | -1150 | - | 13:00 | -0.023 | -0.025 | 13:00 | 0.100 |
| | 17:00 | -1200 | - | 17:00 | -0.036 | -0.036 | 17:00 | 0.110 |
| | 20:00 | -1100 | - | 20:00 | -0.036 | -0.036 | 20:00 | 0.100 |
| 3/25 | 22:30 | -1150 | - | 22:30 | -0.032 | -0.032 | 22:30 | 0.105 |
| | 2:00 | -1300 | - | 2:00 | -0.023 | -0.025 | 2:00 | 0.120 |
| | 6:00 | -1100 | - | 6:00 | -0.020 | -0.020 | 6:00 | 0.120 |
| | 10:00 | -1200 | - | 10:00 | -0.020 | -0.020 | 10:00 | 0.120 |
| | 14:00 | -1400 | - | 14:00 | -0.016 | -0.018 | 14:00 | 0.120 |
| | 15:00 | -1399 | - | 15:00 | -0.016 | -0.018 | 15:00 | 0.120 |
| 3/26 | 18:30 | -1150 | - | 18:30 | -0.020 | -0.018 | 18:30 | 0.120 |
| | 5:00 | -1000 | - | 5:00 | -0.014 | -0.014 | 5:00 | 0.120 |
| | 10:40 | -1100 | - | 10:40 | -0.014 | -0.016 | 10:40 | 0.115 |
| | 13:00 | -1200 | - | 13:00 | -0.027 | -0.027 | 13:00 | 0.110 |
| | 21:00 | -1200 | - | 21:00 | -0.016 | -0.018 | 21:00 | 0.110 |
| 3/27 | 5:00 | -1200 | - | 5:00 | -0.018 | -0.018 | 5:00 | 0.110 |
| | 9:00 | -1200 | - | 9:00 | -0.018 | -0.020 | 9:00 | 0.110 |
| | 15:30 | -1250 | - | 15:30 | -0.018 | -0.020 | 15:30 | 0.110 |
| | 19:20 | -1300 | - | 19:20 | -0.020 | -0.023 | 17:50 | 0.110 |
| 3/28 | 0:00 | -1400 | - | 0:00 | -0.020 | -0.020 | 0:00 | 0.110 |
| | 4:00 | -1500 | - | 4:00 | -0.020 | -0.023 | 4:00 | 0.110 |
| | 12:30 | -1500 | - | 12:30 | -0.032 | -0.032 | 12:30 | 0.100 |
| | 17:30 | -1500 | - | 17:30 | -0.032 | -0.032 | 17:30 | 0.100 |
| 3/29 | 1:00 | -1500 | - | 1:00 | -0.027 | -0.029 | 1:00 | 0.100 |
| | 4:00 | -1500 | - | 4:00 | -0.027 | -0.029 | 4:00 | 0.100 |
| | 10:00 | -1500 | - | 10:00 | -0.025 | -0.027 | 10:00 | 0.100 |
| | 13:00 | -1500 | - | 13:00 | -0.025 | -0.025 | 13:00 | 0.100 |
| | 16:00 | -1500 | - | 16:00 | -0.025 | -0.025 | 16:00 | 0.100 |
| | 22:00 | -1500 | - | 22:00 | -0.032 | -0.032 | 22:00 | 0.100 |
| 3/30 | 6:00 | -1500 | - | 4:00 | -0.025 | -0.025 | 4:00 | 0.100 |
| | 13:00 | -1500 | - | 13:00 | -0.023 | -0.023 | 13:00 | 0.100 |
| | 16:00 | -1500 | - | 16:00 | -0.032 | -0.032 | 16:00 | 0.100 |
| | 18:30 | -1500 | - | 18:30 | -0.029 | -0.027 | 18:30 | 0.100 |
| 3/31 | 2:00 | -1500 | - | 2:00 | -0.025 | -0.025 | 2:00 | 0.110 |
| | 4:00 | -1500 | - | 4:00 | -0.018 | -0.020 | 4:00 | 0.110 |
| | 8:00 | -1500 | - | 8:00 | -0.016 | -0.018 | 8:00 | 0.110 |
| | 16:00 | -1500 | - | 16:00 | -0.009 | -0.011 | 16:00 | 0.110 |

| 2号機 | | | | | | | | |
|-----|-------|-------------|-----|-------------|-------------|--------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | | |
| 4/1 | 0:00 | -1500 | | 0:00 | -0.014 | -0.014 | 0:00 | 0.110 |
| | 6:00 | -1500 | | 6:00 | -0.014 | -0.016 | 6:00 | 0.110 |
| | 10:00 | -1500 | | 10:00 | -0.007 | -0.009 | 10:00 | 0.110 |
| | 16:00 | -1500 | | 16:00 | -0.005 | -0.005 | 16:00 | 0.115 |
| 4/2 | 0:30 | -1500 | | 0:30 | -0.011 | -0.014 | 0:30 | 0.110 |
| | 4:00 | -1500 | | 4:00 | -0.011 | -0.014 | 4:00 | 0.110 |
| | 12:00 | -1550 | | 12:00 | -0.007 | -0.007 | 12:00 | 0.110 |
| | 16:30 | -1500 | | 16:30 | -0.011 | -0.014 | 16:30 | 0.110 |
| 4/3 | 3:00 | -1500 | | 3:00 | -0.016 | -0.018 | 3:00 | 0.105 |
| | 9:00 | -1600 | | 9:00 | -0.016 | -0.018 | 9:00 | 0.105 |
| | 14:00 | -1500 | | 14:00 | -0.016 | -0.016 | 14:00 | 0.110 |
| 4/4 | 0:00 | -1500 | | 0:00 | -0.011 | -0.014 | 0:00 | 0.105 |
| | 6:00 | -1500 | | 6:00 | -0.011 | -0.016 | 6:00 | 0.100 |
| | 11:00 | -1500 | | 11:00 | -0.018 | -0.020 | 11:00 | 0.100 |
| 4/5 | 0:00 | -1500 | | 0:00 | -0.016 | -0.018 | 0:00 | 0.100 |
| | 6:00 | -1500 | | 6:00 | -0.018 | -0.018 | 6:00 | 0.100 |
| | 18:00 | -1500 | | 18:00 | -0.014 | -0.016 | 18:00 | 0.100 |
| 4/6 | 0:00 | -1500 | | 0:00 | -0.018 | -0.023 | 0:00 | 0.100 |
| | 6:00 | -1450 | | 6:00 | -0.016 | -0.020 | 6:00 | 0.100 |
| | 12:00 | -1500 | | 12:00 | -0.016 | -0.018 | 12:00 | 0.100 |
| | 18:00 | -1500 | | 18:00 | -0.014 | -0.018 | 18:00 | 0.100 |
| 4/7 | 0:00 | -1500 | | 0:00 | -0.011 | -0.018 | 0:00 | 0.100 |
| | 6:00 | -1500 | | 6:00 | -0.018 | -0.025 | 6:00 | 0.100 |
| | 12:00 | -1500 | | 12:00 | -0.009 | -0.016 | 12:00 | 0.100 |
| | 19:40 | -1500 | | 19:40 | -0.011 | -0.014 | 19:40 | 0.100 |
| 4/8 | 3:00 | -1500 | | 3:00 | -0.011 | -0.016 | 3:00 | 0.100 |

| 3号機 | | | | | | | | | |
|------|-------|-------------|-------|-------------|-------------|-------|--------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | (C) | | |
| 3/11 | 21:00 | - | - | - | 7.200 | - | - | - | 0.155 |
| 3/12 | 4:15 | 0 | 0 | 4:15 | 7.470 | - | - | 4:15 | 0.285 |
| | 5:20 | 100 | - | 5:20 | 7.400 | - | - | 5:20 | 0.300 |
| | 8:30 | 400 | 60 | 6:30 | 7.520 | - | - | 8:30 | 0.350 |
| | 9:30 | 350 | - | 9:30 | 7.460 | - | - | 9:30 | 0.350 |
| | 11:20 | 200 | - | 9:30 | 7.360 | - | - | 11:20 | 0.350 |
| | 11:20 | 200 | - | 9:30 | 7.360 | - | - | 11:20 | 0.360 |
| | 13:38 | 0 | - | 12:45 | 4.000 | - | - | 13:38 | 0.360 |
| | 13:58 | 420 | - | 13:58 | 3.630 | - | - | 13:58 | 0.360 |
| | 13:58 | 420 | - | 13:58 | 3.630 | - | - | 13:58 | 0.360 |
| | 18:30 | 1200 | - | 18:30 | 1.350 | - | - | 18:30 | 0.280 |
| | 19:00 | 1050 | - | 19:00 | 0.950 | - | - | 19:00 | 0.285 |
| 3/13 | 1:00 | - | - | 1:00 | 0.970 | - | - | 22:00 | 0.270 |
| | 2:00 | - | - | 2:00 | 0.850 | - | - | 22:00 | 0.270 |
| | 8:00 | -3000 | - | 8:00 | 7.270 | - | - | 8:00 | 0.465 |
| | 9:10 | 1800 | - | 9:10 | 7.240 | - | - | 9:10 | 0.637 |
| | 13:00 | -1400 | -2000 | 13:00 | 0.190 | - | - | 13:00 | 0.300 |
| | 16:00 | -1500 | -2000 | 16:00 | 0.180 | - | - | 16:00 | 0.350 |
| | 17:30 | -1800 | -2100 | 17:30 | 0.240 | - | - | 17:30 | 0.415 |
| | 18:45 | -1800 | -2200 | 18:45 | 0.250 | - | - | 18:45 | 0.420 |
| | 21:40 | -1800 | -2200 | 21:40 | - | - | - | 21:40 | 0.320 |
| | 23:00 | -1800 | -2250 | 23:00 | 0.084 | 0.082 | - | 23:00 | 0.265 |
| | 23:30 | -1800 | -2250 | 23:30 | 0.620 | 0.064 | - | 23:30 | 0.250 |
| 3/14 | 0:30 | -1800 | -2250 | 0:30 | 0.048 | 0.048 | - | 0:30 | 0.240 |
| | 2:00 | -1800 | -2250 | 2:00 | 0.073 | 0.075 | - | 2:00 | 0.265 |
| | 3:00 | -1850 | -2300 | 3:00 | 0.127 | 0.127 | - | 3:00 | 0.315 |
| | 4:00 | -1800 | -2800 | 4:00 | 0.150 | 0.150 | - | 4:00 | 0.340 |
| | 5:00 | -2000 | D/S | 5:00 | 0.171 | 0.171 | - | 5:00 | 0.365 |
| | 6:00 | -2350 | - | 6:00 | 0.225 | 0.229 | - | 6:00 | 0.425 |
| | 7:00 | D/S | -3000 | 7:00 | 0.319 | 0.315 | - | 7:00 | 0.520 |
| | 11:15 | -1600 | - | 10:05 | 0.309 | 0.314 | - | 11:15 | 0.380 |
| | 13:00 | -1800 | -2200 | 13:00 | 0.233 | 0.237 | - | 13:00 | 0.430 |
| | 17:00 | -1800 | -2200 | 17:00 | 0.247 | 0.247 | - | 17:00 | 0.440 |
| | 19:00 | -1900 | -2300 | 19:00 | 0.173 | 0.173 | - | 19:00 | 0.360 |
| | 22:45 | -1900 | -2300 | 22:40 | 0.185 | 0.185 | - | 22:45 | 0.370 |
| | 23:30 | -1850 | -2300 | 23:30 | 0.195 | 0.195 | - | 23:30 | - |
| 3/15 | 0:45 | -1900 | -2300 | 0:45 | 0.211 | 0.211 | - | 0:45 | 0.400 |
| | 2:00 | -1900 | -2800 | 2:00 | 0.221 | 0.221 | - | 2:00 | 0.400 |
| | 3:00 | -1900 | -2300 | 3:00 | 0.229 | 0.229 | - | 3:00 | 0.410 |
| | 5:00 | -1800 | -2300 | 5:00 | 0.230 | 0.230 | - | 5:00 | 0.415 |
| | 13:00 | -1900 | -2300 | 13:00 | 0.235 | 0.237 | - | 13:00 | 0.420 |
| | 21:05 | -1900 | -2300 | 21:05 | 0.161 | 0.170 | - | 21:05 | 0.335 |
| 3/16 | 1:35 | -1900 | -2300 | 1:35 | 0.146 | 0.151 | - | 1:35 | 0.320 |
| | 2:20 | -1900 | -2300 | 2:20 | 0.143 | 0.149 | - | 1:35 | 0.320 |
| | 6:15 | -1900 | -2300 | 6:15 | 0.117 | 0.117 | - | 6:15 | 0.295 |
| 3/17 | 0:07 | -1950 | -2300 | 0:07 | 0.010 | 0.017 | - | 0:07 | 0.185 |
| | 7:00 | -1750 | -1750 | 7:00 | 0.024 | 0.032 | - | 7:00 | 0.200 |
| | 16:35 | -1950 | -2300 | 16:35 | 0.005 | 0.017 | - | 16:35 | 0.170 |
| | 22:00 | -1950 | -2300 | 22:00 | -0.009 | 0.005 | - | 22:00 | 0.150 |
| 3/18 | 2:45 | -2000 | -2300 | 2:45 | -0.005 | 0.013 | - | 2:45 | 0.155 |
| | 15:55 | -2000 | -2300 | 15:55 | - | 0.015 | -0.015 | 15:55 | 0.160 |
| | 21:05 | -1900 | -2300 | 21:05 | - | 0.015 | -0.015 | 21:05 | 0.160 |
| 3/19 | 6:10 | -1200 | -2300 | 6:10 | - | 0.005 | 0.043 | 6:10 | 0.185 |
| | 17:25 | -1850 | -2300 | 17:25 | - | 0.081 | -0.047 | 1:25 | 0.210 |
| | 21:50 | -1950 | -2250 | 21:50 | - | 0.115 | 0.083 | 21:50 | 0.255 |

| 3号機 | | | | | | | | | |
|-------|-------|-------------|-------|-------------|-------------|--------|--------|--------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | (C) | | |
| 3/20 | 1:10 | -1950 | -2350 | 1:10 | - | 0.141 | 0.107 | 1:10 | 0.280 |
| | 4:30 | -1950 | -2300 | 4:30 | - | 0.204 | 0.170 | 4:30 | 0.340 |
| | 16:00 | -1650 | -2000 | 16:00 | - | 0.153 | 0.112 | 16:00 | 0.290 |
| 3/21 | 4:00 | -1650 | -1950 | 4:00 | 0.202 | - | -0.026 | 4:00 | 0.160 |
| | 10:00 | -2550 | -2750 | 10:00 | -0.500 | - | -0.043 | 10:00 | 0.120 |
| | 12:15 | -1600 | -2000 | 12:15 | 0.041 | - | -0.078 | 12:15 | 0.120 |
| 3/22 | 14:55 | -1550 | -2025 | 14:55 | 0.043 | - | -0.083 | 14:55 | 0.110 |
| | 0:15 | -1575 | -2250 | 0:15 | 0.041 | - | -0.094 | 0:15 | 0.100 |
| | 5:30 | -1575 | -2350 | 5:30 | 0.036 | - | -0.095 | 5:30 | 0.100 |
| 3/23 | 10:35 | -1575 | -2350 | 10:35 | 0.034 | - | -0.095 | 10:35 | 0.100 |
| | 22:40 | -1750 | -2350 | 22:40 | 0.036 | - | -0.094 | 22:40 | 0.100 |
| | 4:00 | -1900 | -2300 | 4:00 | 0.034 | - | -0.095 | 4:00 | 0.100 |
| 3/24 | 9:10 | -1800 | -2300 | 9:10 | 0.032 | - | -0.098 | 9:10 | 0.100 |
| | 21:40 | -1800 | -2300 | 21:40 | 0.036 | - | -0.098 | 21:40 | D/S |
| | 2:40 | -1800 | -2300 | 2:40 | 0.039 | - | -0.092 | 2:40 | D/S |
| 3/25 | 6:35 | -1800 | -2300 | 6:35 | 0.039 | - | -0.090 | 6:35 | 0.108 |
| | 10:20 | -1900 | -2300 | 10:20 | 0.034 | - | -0.094 | 10:20 | 0.107 |
| | 18:00 | -1850 | -2300 | 18:00 | 0.036 | - | -0.095 | 18:00 | 0.107 |
| 3/26 | 6:10 | -1900 | -2300 | 6:10 | 0.036 | - | -0.092 | 6:10 | 0.1074 |
| | 9:30 | -1900 | -2300 | 9:30 | 0.034 | - | -0.092 | 9:30 | 0.1074 |
| | 14:10 | -1900 | -2300 | 14:10 | 0.036 | - | -0.098 | 14:10 | 0.1089 |
| 3/27 | 16:10 | -1900 | -2300 | 16:10 | 0.034 | - | -0.094 | 16:10 | 0.1075 |
| | 19:10 | -1900 | -2300 | 19:10 | 0.034 | - | -0.098 | 19:10 | 0.1069 |
| | 5:05 | -1850 | -2300 | 5:05 | 0.036 | - | -0.095 | 5:05 | 0.1069 |
| 3/28 | 10:00 | -1800 | -2300 | 10:00 | 0.036 | - | -0.095 | 10:00 | 0.1066 |
| | 11:15 | -1850 | -2300 | 11:15 | 0.036 | - | -0.095 | 11:15 | 0.1068 |
| | 21:20 | -1900 | -2250 | 21:20 | 0.036 | - | -0.098 | 21:20 | 0.1071 |
| 3/29 | 4:45 | -1850 | -2300 | 4:45 | 0.027 | - | -0.094 | 4:45 | 0.1073 |
| | 10:10 | -1900 | -2300 | 10:10 | 0.030 | - | -0.094 | 10:10 | 0.1076 |
| | 16:25 | -1850 | -2300 | 16:25 | 0.032 | - | -0.092 | 16:25 | 0.1069 |
| 3/30 | 19:00 | -1900 | -2300 | 19:00 | 0.030 | - | -0.094 | 19:00 | 0.1080 |
| | 0:00 | -1900 | -2300 | 0:00 | 0.027 | - | -0.087 | 0:00 | 0.1082 |
| | 5:30 | -1900 | -2300 | 5:30 | 0.027 | - | -0.085 | 5:30 | 0.1083 |
| 3/31 | 10:30 | -1850 | -2250 | 10:30 | 0.024 | - | -0.090 | 10:30 | 0.1076 |
| | 16:00 | -1850 | -2300 | 16:00 | 0.030 | - | -0.090 | 16:00 | 0.1078 |
| | 0:00 | -1800 | -2250 | 0:00 | 0.027 | - | -0.087 | 0:00 | 0.1073 |
| 4/1 | 4:45 | -1900 | -2300 | 4:45 | 0.032 | - | -0.085 | 4:45 | 0.1085 |
| | 12:00 | -1850 | -2250 | 12:00 | 0.027 | - | -0.090 | 12:00 | 0.1075 |
| | 16:50 | -1850 | -2250 | 16:50 | 0.027 | - | -0.092 | 16:50 | 0.1069 |
| 4/2 | 23:00 | -1900 | -2300 | 23:00 | 0.027 | - | -0.090 | 23:00 | 0.1069 |
| | 4:00 | -1850 | -2250 | 3:50 | 0.022 | - | -0.087 | 3:50 | 0.1071 |
| | 13:30 | -1850 | -2250 | 13:30 | 0.017 | - | -0.090 | 13:30 | 0.1064 |
| 4/3 | 19:00 | -1850 | -2250 | 19:00 | 0.022 | - | -0.085 | 19:00 | 0.1068 |
| | 23:50 | -1850 | -2250 | 23:50 | 0.019 | - | -0.085 | 23:50 | 0.1073 |
| | 4:40 | -1900 | -2300 | 4:40 | 0.019 | - | -0.085 | 4:40 | 0.1073 |
| 4/4 | 9:40 | -1850 | -2250 | 9:40 | 0.015 | - | -0.087 | 9:40 | 0.1066 |
| | 16:45 | -1950 | -2250 | 16:45 | 0.017 | - | -0.085 | 16:45 | 0.1071 |
| | 0:45 | -1900 | -2250 | 0:45 | 0.015 | - | -0.081 | 0:45 | 0.1073 |
| 4/5 | 5:45 | -1900 | -2250 | 5:45 | 0.017 | - | -0.081 | 5:45 | 0.1071 |
| | 11:45 | -1900 | -2250 | 11:45 | 0.015 | - | -0.083 | 11:45 | 0.1068 |
| | 15:30 | -1850 | -2250 | 15:30 | 0.015 | - | -0.085 | 15:30 | 0.1061 |
| 4/6 | 20:30 | -1850 | -2250 | 20:30 | 0.017 | - | -0.083 | 20:30 | 0.1066 |
| | 1:30 | -1850 | -2250 | 1:30 | 0.024 | - | -0.081 | 1:30 | 0.1055 |
| | 12:10 | -1850 | -2250 | 12:10 | 0.013 | - | -0.090 | 12:10 | 0.1050 |
| 16:30 | -1850 | -2250 | 16:30 | 0.013 | - | -0.085 | 16:30 | 0.1052 | |

| 3号機 | | | | | | | | | |
|-----|-------|-------------|-------|-------------|-------------|-----|--------|-------|---------------|
| 日 | 原子炉水位 | | | 原子炉圧力(MPaG) | | | | D/W圧力 | |
| | 時間 | 水位(TAF)(mm) | | 時間 | 原子炉圧力(MPaG) | | | 時間 | D/W圧力(MPaabs) |
| | | (A) | (B) | | (A) | (B) | (C) | | |
| 4/3 | 2:30 | -1850 | -2250 | 2:30 | 0.010 | | -0.083 | 2:30 | 0.1061 |
| | 10:30 | -1850 | -2250 | 10:30 | 0.010 | | -0.078 | 10:30 | 0.1062 |
| | 13:30 | -1850 | -2250 | 13:30 | 0.010 | | -0.081 | 13:30 | 0.1062 |
| 4/4 | 3:30 | -1850 | -2250 | 3:30 | 0.007 | | -0.077 | 3:30 | 0.1073 |
| | 9:30 | -1750 | 2250 | 9:30 | 0.005 | | -0.078 | 9:30 | 0.1069 |
| 4/5 | 0:30 | -1850 | -2250 | 0:30 | 0.005 | | -0.086 | 0:30 | 0.1069 |
| | 5:40 | -1850 | -2250 | 5:40 | 0.011 | | -0.081 | 5:40 | 0.1078 |
| | 10:20 | -1850 | -2250 | 10:20 | 0.005 | | -0.078 | 10:20 | 0.1071 |
| 4/6 | 18:30 | -1850 | -2250 | 18:30 | 0.007 | | -0.077 | 18:30 | 0.1069 |
| | 0:00 | -1850 | -2250 | 0:00 | 0.009 | | -0.077 | 0:00 | 0.1069 |
| | 6:30 | -1800 | -2200 | 6:30 | 0.007 | | -0.077 | 6:30 | 0.1076 |
| | 12:30 | -1800 | -2200 | 12:30 | 0.005 | | -0.081 | 12:30 | 0.1069 |
| 4/7 | 18:00 | -1800 | -2200 | 18:00 | 0.004 | | -0.081 | 18:00 | 0.1066 |
| | 0:00 | -1850 | -2250 | 0:00 | 0.009 | | -0.079 | 0:00 | 0.1071 |
| | 6:00 | -1850 | -2250 | 6:00 | -0.002 | | -0.079 | 6:00 | 0.1075 |
| | 12:00 | -1900 | -2250 | 12:00 | 0.000 | | -0.081 | 12:00 | 0.1059 |
| 4/8 | 19:30 | -2000 | -2250 | 19:30 | 0.000 | | -0.081 | 19:30 | 0.1062 |
| | 1:30 | -2000 | -2250 | 1:30 | -0.002 | | -0.081 | 1:30 | 0.1061 |
| | 6:00 | | | 6:00 | | | | 6:00 | |
| | 12:00 | | | 12:00 | | | | 12:00 | |
| | 19:30 | | | 19:30 | | | | 19:30 | |

* 1号機・3号機の原子炉圧力については、東電においてデジタル電圧計の測定値の換算式の見直しがあったため、3月13日～4月6日分を修正

福島第一原子力発電所パラメータ

| 4号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/11 | - | - | - | - |
| 3/12 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/13 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/14 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | 4:08 | 84 |
| | - | - | 6:00 | 不明 |
| | - | - | 7:00 | 不明 |
| | - | - | 11:15 | 不明 |
| 3/15 | - | - | 13:00 | 不明 |
| | - | - | 17:00 | 不明 |
| | - | - | 19:00 | 不明 |
| | - | - | 0:00 | 不明 |
| | - | - | 1:00 | 不明 |
| | - | - | 2:00 | 不明 |
| 3/16 | - | - | 6:28 | 不明 |
| | - | - | 13:00 | 不明 |
| | - | - | 21:00 | 不明 |
| | - | - | 1:35 | 不明 |
| 3/17 | - | - | 4:00 | 不明 |
| | - | - | 17:00 | 不明 |
| | - | - | 0:00 | 不明 |
| 3/18 | - | - | 3:00 | 不明 |
| | - | - | 20:00 | 不明 |
| | - | - | 22:00 | 不明 |
| 3/19 | - | - | 6:30 | 不明 |
| | - | - | 18:30 | 不明 |
| | - | - | 23:00 | 不明 |
| 3/20 | - | - | 3:00 | 不明 |
| | - | - | 7:00 | 不明 |
| | - | - | 16:00 | 不明 |
| 3/21 | - | - | 5:00 | 不明 |
| | - | - | 11:00 | 不明 |
| | - | - | 12:00 | 不明 |
| | - | - | 16:00 | 不明 |
| | - | - | 17:00 | 不明 |
| 3/22 | 1:00 | - | 1:00 | 不明 |
| | 5:00 | - | 5:00 | 不明 |
| | 8:00 | - | 8:00 | 不明 |
| | 11:00 | - | 11:00 | 不明 |
| | 14:00 | - | 14:00 | 不明 |
| | 17:00 | - | 17:00 | 不明 |

| 5号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/11 | - | - | - | - |
| 3/12 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/13 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/14 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/15 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/16 | 21:00 | 167.0 | 21:00 | 58.7 |
| | 1:00 | 175.0 | 1:00 | 59.7 |
| | 4:00 | 180.0 | 4:00 | 60.4 |
| | 6:00 | 183.4 | 6:00 | 60.9 |
| | 14:00 | 196.2 | 14:00 | 62.7 |
| 3/17 | 4:00 | 168.8 | 4:00 | 64.5 |
| | 17:00 | 186.2 | 17:00 | 64.5 |
| | 0:00 | 196.5 | 0:00 | 65.1 |
| 3/18 | 3:00 | 163.1 | 3:00 | 65.5 |
| | 16:00 | 187.1 | 16:00 | 66.9 |
| | 21:00 | 194.8 | 21:00 | 67.6 |
| | 6:00 | 173.1 | 6:00 | 68.8 |
| 3/19 | 18:00 | 194.5 | 18:00 | 48.1 |
| | 23:00 | 164.5 | 23:00 | 43.1 |
| | 3:00 | 173.5 | 3:00 | 43.1 |
| 3/20 | 7:00 | 185.0 | 7:00 | 36.1 |
| | 16:00 | 76.5 | 16:00 | 35.1 |
| | 5:00 | 34.4 | 5:00 | 39.5 |
| 3/21 | 11:00 | 31.2 | 11:00 | 41.9 |
| | 12:00 | 31.0 | 12:00 | 42.2 |
| | 16:00 | 53.2 | 16:00 | 42.3 |
| | 17:00 | 55.2 | 17:00 | 42.3 |
| | 1:00 | 53.9 | 1:00 | 35.8 |
| 3/22 | 5:00 | 39.3 | 5:00 | 36.3 |
| | 8:00 | 46.3 | 8:00 | 37.4 |
| | 11:00 | 53.2 | 11:00 | 37.5 |
| | 14:00 | 61.7 | 14:00 | 36.9 |
| | 17:00 | 70.6 | 17:00 | 33.5 |

| 6号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/11 | - | - | - | - |
| 3/12 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/13 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/14 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/15 | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| | - | - | - | - |
| 3/16 | 21:00 | 155.7 | 21:00 | 57.0 |
| | 1:00 | 154.9 | 1:00 | 58.0 |
| | 4:00 | 148.3 | 4:00 | 58.5 |
| | 6:00 | 149.9 | 6:00 | 59.0 |
| 3/17 | 14:00 | 150.0 | 14:00 | 60.0 |
| | 4:00 | 162.7 | 4:00 | 61.0 |
| | 17:00 | 153.5 | 17:00 | 64.0 |
| 3/18 | 0:00 | 159.7 | 0:00 | 61.6 |
| | 3:00 | 157.1 | 3:00 | 62.0 |
| | 16:00 | 156.7 | 16:00 | 64.5 |
| | 21:00 | 159.2 | 21:00 | 65.0 |
| 3/19 | 6:00 | 164.1 | 6:00 | 66.5 |
| | 18:00 | 152.4 | 18:00 | 67.0 |
| | 23:00 | 156.6 | 23:00 | 67.5 |
| 3/20 | 3:00 | 159.4 | 3:00 | 52.0 |
| | 7:00 | 185.0 | 7:00 | 36.5 |
| | 16:00 | 167.5 | 16:00 | 28.0 |
| 3/21 | 5:00 | 28.2 | 5:00 | 32.0 |
| | 11:00 | 23.1 | 11:00 | 34.0 |
| | 12:00 | 22.8 | 12:00 | 35.0 |
| | 16:00 | 23.6 | 16:00 | 36.0 |
| | 17:00 | 23.0 | 17:00 | 36.5 |
| 3/22 | 0:00 | 46.0 | 1:00 | 30.0 |
| | 5:00 | 55.3 | 5:00 | 26.0 |
| | 8:00 | 59.6 | 8:00 | 23.5 |
| | 11:00 | 34.1 | 11:00 | 25.0 |
| | 14:00 | 26.5 | 14:00 | 26.0 |
| | 17:00 | 21.6 | 17:00 | 27.5 |

| 4号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/23 | 0:00 | - | 0:00 | 不明 |
| | 6:00 | - | 6:00 | 不明 |
| | 9:00 | - | 9:00 | 不明 |
| | 12:00 | - | 12:00 | 不明 |
| | 14:00 | - | 14:00 | 不明 |
| | 18:00 | - | 18:00 | 不明 |
| 3/24 | 21:10 | - | 21:10 | 100.0 |
| 3/24 | 2:40 | - | 2:40 | 100.0 |
| | 6:35 | - | 6:35 | 計器不良 |
| | 11:00 | - | 11:00 | 計器不良 |
| | 13:00 | - | 13:00 | 計器不良 |
| | 17:00 | - | 17:00 | 計器不良 |
| | 19:00 | - | 19:00 | 計器不良 |
| 3/25 | 23:00 | - | 23:00 | 計器不良 |
| | 1:00 | - | 1:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 10:00 | - | 10:00 | 計器不良 |
| | 11:00 | - | 11:00 | 計器不良 |
| | 18:00 | - | 18:00 | 計器不良 |
| 3/26 | 20:00 | - | 20:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 11:00 | - | 11:00 | 計器不良 |
| | 14:00 | - | 14:00 | 計器不良 |
| | 21:20 | - | 21:20 | 計器不良 |
| | 3/27 | 6:00 | - | 6:00 |
| 3/27 | 10:10 | - | 10:10 | 計器不良 |
| | 16:25 | - | 16:25 | 計器不良 |
| | 20:00 | - | 20:00 | 計器不良 |
| | 3/28 | 1:00 | - | 1:00 |
| 3/28 | 6:00 | - | 6:00 | 計器不良 |
| | 10:30 | - | 10:30 | 計器不良 |
| | 16:00 | - | 16:00 | 計器不良 |
| 3/29 | 2:00 | - | 2:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 12:00 | - | 12:00 | 計器不良 |
| | 14:00 | - | 14:00 | 計器不良 |
| | 18:00 | - | 18:00 | 計器不良 |
| 3/30 | 23:00 | - | 23:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 13:30 | - | 14:00 | 計器不良 |
| | 18:00 | - | 18:00 | 計器不良 |
| 3/31 | 23:00 | - | 23:00 | 計器不良 |
| | 4:00 | - | 4:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 11:00 | - | 11:00 | 計器不良 |
| 4/1 | 18:00 | - | 18:00 | 計器不良 |
| | 2:00 | - | 2:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 12:00 | - | 12:00 | 計器不良 |
| | 14:00 | - | 14:00 | 計器不良 |
| 4/2 | 18:00 | - | 18:00 | 計器不良 |
| | 2:00 | - | 2:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 14:00 | - | 14:00 | 計器不良 |
| 4/3 | 20:00 | - | 20:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 11:00 | - | 11:00 | 計器不良 |
| | 13:00 | - | 13:00 | 計器不良 |
| 4/4 | 16:00 | - | 16:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 8:00 | - | 8:00 | 計器不良 |
| 4/5 | 14:00 | - | 14:00 | 計器不良 |
| | 3:00 | - | 3:00 | 計器不良 |
| | 7:00 | - | 7:00 | 計器不良 |
| 4/6 | 13:00 | - | 13:00 | 計器不良 |
| | 19:00 | - | 19:00 | 計器不良 |
| | 5:00 | - | 5:00 | 計器不良 |
| 7:00 | - | 7:00 | 計器不良 | |

| 5号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/23 | 0:00 | 44.3 | 0:00 | 34.2 |
| | 6:00 | 34.2 | 6:00 | 36.6 |
| | 9:00 | 31.9 | 9:00 | 37.8 |
| | 12:00 | 30.7 | 12:00 | 39.0 |
| | 14:00 | 30.2 | 14:00 | 39.0 |
| | 18:00 | 40.9 | 18:00 | 41.1 |
| | 22:00 | 50.7 | 22:00 | 42.6 |
| 3/24 | 5:00 | 71.4 | 5:00 | 45.1 |
| | 9:00 | 81.7 | 9:00 | 46.4 |
| | 11:00 | 86.8 | 11:00 | 47.2 |
| | 13:00 | 92.0 | 13:00 | 47.7 |
| | 17:00 | 82.7 | 17:00 | 49.0 |
| | 19:00 | 61.4 | 19:00 | 49.8 |
| 3/25 | 23:00 | 44.8 | 23:00 | 50.9 |
| | 1:00 | 51.4 | 1:00 | 50.9 |
| | 6:00 | 65.8 | 6:00 | 49.3 |
| | 10:00 | 77.0 | 10:00 | 39.5 |
| | 15:00 | 53.9 | 15:00 | 36.9 |
| | 18:00 | 43.2 | 18:00 | 37.9 |
| | 20:00 | 38.6 | 20:00 | 38.8 |
| 3/26 | 0:25 | 30.3 | 6:00 | 42.3 |
| | 11:00 | 36.5 | 11:00 | 43.7 |
| | 14:00 | 43.8 | 14:00 | 42.8 |
| | 22:00 | 66.2 | 22:00 | 34.1 |
| | 3/27 | 6:00 | 43.2 | 6:00 |
| 3/27 | 14:00 | 30.3 | 14:00 | 37.8 |
| | 17:00 | 29.5 | 17:00 | 38.8 |
| | 20:00 | 28.9 | 20:00 | 39.9 |
| 3/28 | 1:00 | 43.1 | 1:00 | 39.7 |
| | 6:00 | 57.7 | 6:00 | 34.5 |
| | 14:00 | 50.6 | 14:00 | 30.9 |
| | 19:00 | 37.8 | 19:00 | 32.8 |
| 3/29 | 2:00 | 31.4 | 2:00 | 35.5 |
| | 6:00 | 29.8 | 6:00 | 37.1 |
| | 12:00 | 35.0 | 12:00 | 38.8 |
| | 14:00 | 40.5 | 14:00 | 38.6 |
| | 18:00 | 51.8 | 18:00 | 34.5 |
| | 23:00 | 51.2 | 23:00 | 32.4 |
| 3/30 | 6:00 | 34.7 | 6:00 | 34.2 |
| | 14:00 | 29.9 | 14:00 | 37.2 |
| | 18:00 | 29.2 | 18:00 | 38.7 |
| | 23:00 | 42.3 | 23:00 | 38.5 |
| | 3/31 | 4:00 | 56.3 | 4:00 |
| 4/1 | 6:00 | 61.9 | 6:00 | 32.4 |
| | 11:00 | 62.4 | 11:00 | 30.0 |
| | 18:00 | 37.7 | 18:00 | 32.0 |
| | 2:00 | 30.9 | 2:00 | 35.1 |
| 4/2 | 6:00 | 29.8 | 6:00 | 36.6 |
| | 12:00 | 34.5 | 12:00 | 38.4 |
| | 14:00 | 40.9 | 14:00 | 38.1 |
| | 18:00 | 52.3 | 18:00 | 34.4 |
| | 2:00 | 42.4 | 2:00 | 32.6 |
| | 6:00 | 35.5 | 6:00 | 34.1 |
| 4/3 | 14:00 | 30.4 | 14:00 | 37.1 |
| | 20:00 | 37.2 | 20:00 | 38.3 |
| | 6:00 | 65.5 | 6:00 | 31.0 |
| | 11:00 | 62.9 | 11:00 | 29.1 |
| | 13:00 | 51.5 | 13:00 | 29.7 |
| 4/4 | 16:00 | 41.8 | 16:00 | 30.9 |
| | 6:00 | 29.9 | 6:00 | 36.1 |
| | 8:00 | 29.6 | 8:00 | 36.8 |
| 4/5 | 14:00 | 44.0 | 14:00 | 34.6 |
| | 3:00 | 36.0 | 3:00 | 34.0 |
| | 7:00 | 32.8 | 7:00 | 35.5 |
| 4/6 | 13:00 | 42.4 | 13:00 | 34.8 |
| | 19:00 | 59.0 | 19:00 | 31.4 |
| | 5:00 | 33.3 | 5:00 | 34.4 |
| 7:00 | 32.1 | 7:00 | 35.1 | |

| 6号機 | | | | |
|------|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| 3/23 | 0:00 | 43.1 | 0:00 | 24.5 |
| | 6:00 | 64.0 | 6:00 | 21.0 |
| | 9:00 | 59.1 | 9:00 | 20.0 |
| | 12:00 | 64.6 | 12:00 | 20.0 |
| | 14:00 | 68.1 | 14:00 | 19.5 |
| | 18:00 | 75.7 | 18:00 | 19.0 |
| | 22:00 | 35.7 | 22:00 | 20.5 |
| 3/24 | 5:00 | 24.1 | 5:00 | 23.5 |
| | 9:00 | 24.3 | 9:00 | 25.0 |
| | 11:00 | 24.4 | 11:00 | 26.0 |
| | 13:00 | 22.3 | 12:00 | 27.0 |
| | 17:00 | 21.3 | 17:00 | 28.5 |
| | 19:00 | 31.8 | 19:00 | 28.5 |
| 3/25 | 23:00 | 37.1 | 23:00 | 24.0 |
| | 1:00 | 42.3 | 1:00 | 22.5 |
| | 6:00 | 50.2 | 6:00 | 20.5 |
| | 10:00 | 57.4 | 10:00 | 19.5 |
| | 15:00 | 29.9 | 15:00 | 21.0 |
| | 18:00 | 26.9 | 18:00 | 22.0 |
| | 20:00 | 23.8 | 20:00 | 23.0 |
| 3/26 | 6:00 | 22.1 | 6:00 | 27.0 |
| | 11:00 | 21.3 | 11:00 | 29.0 |
| | 14:00 | 21.3 | 14:00 | 30.0 |
| | 22:00 | 34.8 | 22:00 | 27.0 |
| | 3/27 | 6:00 | 49.4 | 6:00 |
| 3/27 | 14:00 | 29.1 | 14:00 | 21.0 |
| | 17:00 | 24.9 | 17:00 | 22.5 |
| | 20:00 | 23.3 | 20:00 | 24.0 |
| 3/28 | 1:00 | 22.3 | 1:00 | 25.5 |
| | 6:00 | 21.9 | 6:00 | 27.5 |
| | 14:00 | 22.3 | 14:00 | 30.5 |
| | 19:00 | 22.7 | 19:00 | 32.8 |
| | 3/29 | 2:00 | 41.7 | 2:00 |
| 3/29 | 6:00 | 48.9 | 6:00 | 22.0 |
| | 12:00 | 37.7 | 12:00 | 21.0 |
| | 14:00 | 30.3 | 14:00 | 21.5 |
| | 18:00 | 27.1 | 18:00 | 23.0 |
| | 23:00 | 23.3 | 23:00 | 25.0 |
| | 6:00 | 21.6 | 6:00 | 28.0 |
| 3/30 | 14:00 | 32.6 | 14:00 | 26.5 |
| | 18:00 | 40.9 | 18:00 | 23.0 |
| | 23:00 | 37.2 | 23:00 | 21.0 |
| | 3/31 | 4:00 | 26.9 | 4:00 |
| 4/1 | 6:00 | 24.0 | 6:00 | 24.0 |
| | 11:00 | 22.3 | 11:00 | 26.0 |
| | 18:00 | 21.1 | 18:00 | 29.0 |
| | 2:00 | 37.4 | 2:00 | 24.0 |
| 4/2 | 6:00 | 44.1 | 6:00 | 22.0 |
| | 12:00 | 44.7 | 12:00 | 20.0 |
| | 14:00 | 33.3 | 14:00 | 21.0 |
| | 18:00 | 24.6 | 18:00 | 22.5 |
| | 2:00 | 22.0 | 2:00 | 25.5 |
| | 6:00 | 21.6 | 6:00 | 27.0 |
| 4/3 | 14:00 | 31.8 | 14:00 | 25.5 |
| | 20:00 | 28.6 | 20:00 | 23.0 |
| | 6:00 | 23.2 | 6:00 | 27.0 |
| | 11:00 | 22.8 | 11:00 | 29.0 |
| | 13:00 | 22.7 | 13:00 | 29.5 |
| 4/4 | 16:00 | 22.7 | 16:00 | 30.5 |
| | 6:00 | 48.0 | 6:00 | 21.5 |
| | 8:00 | 51.6 | 8:00 | 21.0 |
| 4/5 | 14:00 | 30.1 | 14:00 | 21.5 |
| | 3:00 | 22.7 | 3:00 | 27.0 |
| | 7:00 | 22.5 | 7:00 | 28.5 |
| 4/6 | 13:00 | 30.9 | 13:00 | 27.5 |
| | 19:00 | 42.0 | 19:00 | 23.5 |
| | 5:00 | 23.6 | 5:00 | 26.0 |
| 7:00 | 22.5 | 7:00 | 26.5 | |

| 4号機 | | | | |
|-----|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| | 13:00 | - | 13:00 | 計器不良 |
| | 20:00 | - | 20:00 | 計器不良 |
| 4/7 | 2:00 | - | 2:00 | 計器不良 |
| | 6:00 | - | 6:00 | 計器不良 |
| | 12:00 | - | 12:00 | 計器不良 |
| | 21:00 | - | 20:00 | 計器不良 |
| 4/7 | 6:00 | - | 6:00 | 計器不良 |
| | | - | | 計器不良 |
| | | - | | 計器不良 |
| | | - | | 計器不良 |

| 5号機 | | | | |
|-----|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| | 13:00 | 42.3 | 13:00 | 35.2 |
| | 20:00 | 49.8 | 20:00 | 31.3 |
| 4/7 | 2:00 | 36.4 | 2:00 | 33.0 |
| | 6:00 | 34.8 | 6:00 | 34.8 |
| | 12:00 | 39.1 | 12:00 | 36.0 |
| | 21:00 | 46.6 | 20:00 | 31.6 |
| | 6:00 | 33.2 | 6:00 | 34.8 |
| 4/7 | | | | |
| | | | | |
| | | | | |

| 6号機 | | | | |
|-----|--------|------------|-----------------|------------|
| 日 | 原子炉水温度 | | 使用済燃料 プール水温度 | |
| | 時間 | 温度 (°C) | 時間 | 温度 (°C) |
| | 13:00 | 21.1 | 13:00 | 29.5 |
| | 20:00 | 29.4 | 20:00 | 28.0 |
| 4/7 | 2:00 | 40.6 | 2:00 | 23.5 |
| | 6:00 | 48.1 | 6:00 | 21.5 |
| | 12:00 | 37.1 | 12:00 | 21.0 |
| | 21:00 | 22.2 | 20:00 | 24.5 |
| | 6:00 | 22.1 | 6:00 | 28.0 |
| 4/7 | | | | |
| | | | | |
| | | | | |